



Rajashree

Fire & Safety Services



All Types Of Fire Protection Equipments Sales & Services , Supplier & Stockist Industrial Safety Appliances

Date – 06/06/2025

Ref – RFS /25-26/222

CERTIFICATE

This is to certify that **L. H. PATIL ENGLISH MEDIUM SCHOOL**. Has Refilled, reconditioned, leakage check, Discharge & H.P tested as per and conforming to I.S 2190:2010 (Selection, installation and maintenance of first – aid fire extinguisher). The details of work done for fire extinguisher are as follows.

Sr. No	Type of Fire Extinguisher	Capacity	Nos
1	ABC TYPE FIRE EXTINGUISHER	5 KG	3 NOS
2	ABC TYPE FIRE EXTINGUISHER	4 KG	2 NOS
3	ABC TYPE FIRE EXTINGUISHER	9 KG	1 NOS
4	ABC TYPE FIRE EXTINGUISHER	2 KG	5 NOS
5	ABC TYPE FIRE EXTINGUISHER	1 KG	6 NOS
6	DCP TYPE FIRE EXTINGUISHER	5 KG	3 NOS
7	CO2 TYPE FIRE EXTINGUISHER	4.5 KG	1 NOS

Refilling Date – 06/06/2025

Next due date – 05/06/2026

Place – Jalgaon

Date – 06/06/2025

